

4


3

2

1

NOTES:

- A. BASE LAYER OF 1-1/2" X 2-1/2" CAN BE ADDED
- B. ALL GRAVEL TO BE HAND LEVELLED
- C. CARE MUST BE TAKEN WHEN INSTALLING GRAVEL TO NOT DAMAGE UNDER DRAINS



TORPEDO SAND, EFFECTIVE SIZE 0.8-1.2mm, 3-4" (75-100mm) DEPTH. GARNET ALSO ACCEPTABLE

GRADED GRAVEL 1/8" X 1/4", 3-4" DEPTH (3mm X 6mm, 75-100mm DEPTH)

GRADED GRAVEL 1/4" X 1/2", 3-4" DEPTH (6mm X 12mm, 75-100mm DEPTH)

GRADED GRAVEL 1/2" X 3/4", 3-4" DEPTH (12mm X 19mm, 75-100mm DEPTH)


GRADED GRAVEL 3/4" X 1-1/2", 3-4" DEPTH (19mm X 37mm, 75-100 mm DEPTH) MEASURED FROM TOP OF UNDERDRAIN

TOP OF UNDERDRAIN

TOLERANCES  
UNLESS OTHERWISE SPECIFIED  
3 DECIMAL = +/- .005  
2 DECIMAL = +/- .010  
1 DECIMAL = +/- .020  
FRACTIONAL = +/- .062

UNLESS OTHERWISE SPECIFIED,  
ALL DIMENSIONS ARE IN  
INCHES

THIRD ANGLE PROJECTION



**CONFIDENTIAL**

THIS DRAWING AND ALL INFORMATION CONCERNING IT IS CONFIDENTIAL, PROPRIETARY AND/OR A TRADE SECRET TO WATERPOLIS CORP. POSSESSION OF THE DRAWING CONSTITUTES AGREEMENT TO MAINTAIN THE DRAWING AND ALL INFORMATION CONCERNING IT AS CONFIDENTIAL, PROPRIETARY AND/OR TRADE SECRET TO WATERPOLIS CORP. NEITHER THE DRAWING NOR ANY INFORMATION CONCERNING IT MAY BE COPIED, EXHIBITED, OR FURNISHED TO OTHERS WITHOUT WRITTEN PERMISSION FROM WATERPOLIS CORP. THE DRAWING AND INFORMATION CONCERNING IT SHALL BE RETURNED ON REQUEST.

REV 01/09



GRAVITY FILTER

DATE	APR-6-2019	DRAWN	MM	SIZE	B	DWG NO		REV	01
WT	lbs	APVD		SCALE	NTS	SHEET	SHEET 1 OF 1		

4

3

2

1

B

B

A

A